

PROJECT NAME: Enstar - W Tidelands reroute				PROJECT NO.: 209131	
CALC: Wind(ASCE 7-16 WLOS) Pipes				PAGE: 1 of 4	
CALC BY: BPA	DATE: 9/23/2025	CHK BY: XXX	DATE: xx/xx/2025	APPRV BY: XXX	DATE: xx/xx/2025

**ASCE 7-16: CHAPTER 29 WIND LOAD ON BUILDING APPURTENANCES AND OTHER STRUCTURES: MWFRS (DIRECTIONAL PROCEDURE)**

**Pipe and Support**

Risk Category (Table 1.5-1):  $RC$

$RC := \text{III } \checkmark$

Assumptions: See Table for additional info.

RC I - Bldg. and Structures represent low risk to life in the event of failure

RC II - All Bldg. and Structures except listed in RC I, III, and IV

RC III - Bldg. and Structures failure could pose a substantial risk to human life

RC IV - Bldg. and Structures designated as essential facilities

LRFD Wind Importance Factor by Risk Category:  $I_w$

$I_w := RC_1 = 1.00$

Wind Exposure/Surface Roughness (Sec 26.7.3)

$EXP := \text{B } \checkmark$

Assumptions: See section for additional info.

Exp. B - Bldg. and Structures with mean roof height less than or equal to 30 ft

Exp. C - Apply for all case where Exp B or D does not apply

Exp. D - Apply where ground surface roughness for distance greater than 5,000 ft or

20 times the building height. Flat, unobstructed areas and water surface,  
includes smooth mud flats, salt flats, and unbroken ice.

Basic Wind Speed 3-sec Gust (Section 26.5):  $V$

$V := 160 \text{ mph}$

(Assumptions: ASCE Figure 26.5-1A thru 26.5-2D, MOA Wind Map, Zone IV)

Estimated height above ground surface of the structure:  $z$

$z := 4.53 \text{ ft}$

Height above ground surface of the component:  $h$

$h := z = 4.53 \text{ ft}$

Structure Type (Table 26.6-1):  $Type \equiv \text{d1} \text{ Chimneys, Tanks, and Sim. Struc: Round } \checkmark$

Terrain Exposure Constants (Table 26.11-1):  $\alpha$  and  $z_g$

$\alpha := EXP_1 = 7.0$

(Assumptions:  $EXP_0 = \text{"B"}$  )

$z_g := EXP_2 = 1200 \text{ ft}$

Velocity Pressure Exposure Coefficient (Table 26.10-1):  $K_z$

$K_z := \begin{cases} \text{if } 15 \text{ ft} \leq z \leq z_g \\ 2.01 \cdot \left(\frac{z}{z_g}\right)^{\frac{2}{\alpha}} \end{cases}$

(Assumptions: Notes 1.

$\text{else}$

For:  $15 \text{ ft} \leq z \leq z_g$

$2.01 \cdot \left(\frac{15 \text{ ft}}{z_g}\right)^{\frac{2}{\alpha}}$

For:  $z < 15 \text{ ft}$

$K_z = 0.57$

Topographic Factor (Section 26.8.2):  $K_{zt}$

$K_{zt} := 1.0$

(Assumptions: All conditions specified in Section 26.8.1 are not met. Lake Walkway  
not on hill or escarpment)

Wind Directionality Factor (Table 26.6-1):  $K_d$

$K_d := Type_0 = 1.00$

Assumptions:

[Used only in conjunction with ASCE Load Combinations, i.e. not deflection]

PROJECT NAME: Enstar - W Tidelands reroute				PROJECT NO.: 209131	
CALC: Wind(ASCE 7-16 WLOS) Pipes				PAGE: 2 of 4	
CALC BY: BPA	DATE: 9/23/2025	CHK BY: XXX	DATE: xx/xx/2025	APPRV BY: XXX	DATE: xx/xx/2025

Ground Elevation Factor (Table 26.9-1):  $K_e$

(Assumptions: Note 1 and 3 permitted in all cases)

$$K_e := 1.00$$

Gust Effect Factor (Section 26.11.1):  $G$

$$G := 0.85$$

Velocity Pressure @ Height "z" (EQ 26.10-1):  $q_z$

$$q_z := 0.00256 \cdot K_z \cdot K_{zt} \cdot K_d \cdot K_e \cdot V^2 \left( \frac{\text{psf}}{\text{mph}^2} \right)$$

$$q_z = 37.7 \text{ psf}$$

$$q_h := q_z = 37.7 \text{ psf}$$

## **DESIGN WIND FORCE AND COEFFICIENTS CALCULATIONS:**

### **Non-Insulated Round Member**

Force Coefficients, $C_f$						
Cross Section	Type of Surface	h/D				
		1	7	25		
Square (wind normal to face)	All	1.3	1.4	2.0		
Square (wind along diagonal)	All	1.0	1.1	1.5		
Hexagonal or octagonal	All	1.0	1.2	1.4		
Round, $D\sqrt{q_z} > 2.5$	Moderately smooth	0.5	0.6	0.7		
$D\sqrt{q_z} > 5.3$ (in S.I.)	Rough ( $D'/D = 0.02$ )	0.7	0.8	0.9		
$D\sqrt{q_z} > 5.3$ (in S.I.)	Very rough ( $D'/D = 0.08$ )	0.8	1.0	1.2		
Round, $D\sqrt{q_z} \leq 2.5$ $D\sqrt{q_z} \leq 5.3$ (in S.I.)	All	0.7	0.8	1.2		

**Notation**

$D$  = Diameter of circular cross section and least horizontal dimension of square, hexagonal, or octagonal cross sections at elevation under consideration, in ft (m)  
 $D'$  = Depth of protruding elements such as ribs and spoilers, in ft (m)  
 $h$  = Height of structure, in ft (m)  
 $q_z$  = Velocity pressure evaluated at height  $z$  above ground, in  $\text{lb}/\text{ft}^2$  ( $\text{N}/\text{m}^2$ ).

**Notes**

1. The design wind force shall be calculated based on the area of the structure projected on a vertical plane normal to the wind direction.  
The force shall be assumed to act parallel to the wind direction.
2. Linear interpolation is permitted for  $h/D$  values other than shown.

FIGURE 29.4-1 Other Structures (All Heights): Force Coefficients,  $C_f$ , for Chimneys, Tanks, and Similar Structures

## **Functions:**

Force Coefficients ( $C_f$ ):

(Assumptions Applied to all round members, with or without insulation)

$Cross\_Section_{RND1} \equiv \text{Round } D * \text{sqrt}(q_z) > 2.5: \text{Moderately Smooth} \checkmark$

$Cross\_Section_{RND2} \equiv \text{Round } D * \text{sqrt}(q_z) \leq 2.5: \text{All} \checkmark$

$$h/D = \begin{bmatrix} 1 \\ 7 \\ 25 \end{bmatrix} \quad C_{f\_rnd1} = \begin{bmatrix} 0.5 \\ 0.6 \\ 0.7 \end{bmatrix} \quad C_{f\_rnd2} = \begin{bmatrix} 0.7 \\ 0.8 \\ 1.2 \end{bmatrix}$$

$$C_f(h, D, CS_{RND}) \equiv \text{interp}\left(h/D, C_f, \frac{h}{D}\right)$$

General Interpolation EQ for:  $h/D$ :  $C_f$

Projected Unit Area Normal to Wind:  $A_{f2}$

(Assumptions:  $h/D$ ; Round Moderately Smooth surface)

$$A_{f2} := 1.0 \cdot \text{ft}^2$$

Design Wind Loads Other Structures (WLOS)  
(EQ 29.4-1):  $F$

$$F = q_z \cdot G \cdot C_f \cdot A_{f2} \cdot (\text{psf})$$

PROJECT NAME: Enstar - W Tidelands reroute	PROJECT NO.: 209131
CALC: Wind(ASCE 7-16 WLOS) Pipes	PAGE: 3 of 4
CALC BY: BPA	DATE: 9/23/2025

## ROUND SHAPES (NON-INSULATED PIPES)

**Member Diameter:** Pipe 8" Dia

Diameter or least horizontal dimension of square, hexagonal or octagonal section:  $D_{8\phi}$

**Check:** Minimum Cross Section w/o insulation:  $CS_{8\phi}$

(Assumptions: Round,  $D \cdot \sqrt{q_z}$  surface, w/ or w/o insulation)

$$D_8 = 8.625 \text{ in}$$

$$D_{8\phi} := D_8 = 0.7 \text{ ft}$$

$$CS_{8\phi} := \frac{D_{8\phi}}{\text{ft}} \cdot \sqrt{\frac{q_z}{\text{psf}}} = 4.4 > 2.5$$

$$\frac{h}{D_{8\phi}} = 6.3$$

$$C_{f8\phi} := C_{f,RND}(h, D_{8\phi}, CS_{8\phi})$$

$$C_{f8\phi} = 0.59$$

Structure Height-to-Diameter ratio ( Fig 29.4-1):  $h/D$

Force Coefficients (Figure 29.4-1):  $C_{f8\phi}$

Design Wind Force per Unit Area:  $F_8$

$$F_8 := q_z \cdot G \cdot C_{f8\phi} \cdot A_{f2} \cdot (\text{ft}^2)^{-1}$$

$$F_8 = 18.8 \text{ psf}$$

Design Wind Force per Length for Pipe 8" Dia:  $F_{8\phi}$

$$F_{8\phi} := F_8 \cdot (D_{8\phi}) = 13.5 \text{ plf}$$

**Member Diameter:** Pipe 12" Dia

Diameter or least horizontal dimension of square, hexagonal or octagonal section:  $D_{12\phi}$

**Check:** Minimum Cross Section w/o insulation:  $CS_{12\phi}$

(Assumptions: Round,  $D \cdot \sqrt{q_z}$  surface, w/ or w/o insulation)

$$D_{12} = 12.75 \text{ in}$$

$$D_{12\phi} := D_{12} = 1.1 \text{ ft}$$

$$CS_{12\phi} := \frac{D_{12\phi}}{\text{ft}} \cdot \sqrt{\frac{q_z}{\text{psf}}} = 6.5 > 2.5$$

$$\frac{h}{D_{12\phi}} = 4.3$$

$$C_{f12\phi} := C_{f,RND}(h, D_{12\phi}, CS_{12\phi})$$

$$C_{f12\phi} = 0.55$$

Structure Height-to-Diameter ratio ( Fig 29.4-1):  $h/D$

Force Coefficients (Figure 29.4-1):  $C_{f12\phi}$

Design Wind Force per Unit Area:  $F_{12}$

$$F_{12} := q_z \cdot G \cdot C_{f12\phi} \cdot A_{f2} \cdot (\text{ft}^2)^{-1}$$

$$F_{12} = 17.7 \text{ psf}$$

Design Wind Force per Length for Pipe 12" Dia:  $F_{12\phi}$

$$F_{12\phi} := F_{12} \cdot (D_{12\phi}) = 18.9 \text{ plf}$$

**Member Diameter:** Pipe 7" Dia Pile

Diameter or least horizontal dimension of square, hexagonal or octagonal section,  $D_{7\phi\_Pile}$

**Check:** Minimum Cross Section w/o insulation,  $CS_{7\phi\_Pile}$

(Assumptions: Round,  $D \cdot \sqrt{q_z}$  surface, w/ or w/o insulation)

$$D_7 = 7 \text{ in}$$

$$D_{7\phi\_Pile} := D_7 = 0.58 \text{ ft}$$

$$CS_{7\phi\_Pile} := \frac{D_{7\phi\_Pile}}{\text{ft}} \cdot \sqrt{\frac{q_z}{\text{psf}}} = 3.6 > 2.5$$

PROJECT NAME: Enstar - W Tidelands reroute	PROJECT NO.: 209131
CALC: Wind(ASCE 7-16 WLOS) Pipes	PAGE: 4 of 4
CALC BY: BPA	DATE: 9/23/2025

Structure Height-to-Diameter ratio ( Fig 29.4-1):  $h/D$ 

$$\frac{h}{D_{7\phi\_Pile}} = 7.8$$

Force Coefficients (Figure 29.4-1):  $C_{f7\phi\_Pile}$ 

$$C_{f7\phi\_Pile} := C_{f\_RND}(h, D_{7\phi\_Pile}, CS_{7\phi\_Pile})$$

$$C_{f7\phi\_Pile} = 0.6$$

Design Wind Force per Unit Area:  $F_{7\_Pile}$ 

$$F_{7\_Pile} := q_z \cdot G \cdot C_{f7\phi\_Pile} \cdot A_{f2} \cdot (ft^2)^{-1}$$

$$F_{7\_Pile} = 19.3 \text{ psf}$$

Design Wind Force per Length for Pipe 7" Dia:  $F_{7\phi\_Pile}$ 

$$F_{7\phi\_Pile} := F_{7\_Pile} \cdot (D_{7\phi\_Pile}) = 11.3 \text{ plf}$$

**Summary:****ROUND SHAPES (NON-INSULATED PIPES)**Design Wind Force per Length for Pipe 8" Dia,  $F_{8\phi}$ 

$$F_{8\phi} = 0.014 \text{ klf}$$

Design Wind Force per Length for Pipe 12" Dia,  $F_{12\phi}$ 

$$F_{12\phi} = 0.019 \text{ klf}$$

Design Wind Force per Length for Pile 7" Dia,  $F_{7\phi\_Pile}$ 

$$F_{7\phi\_Pile} = 0.011 \text{ klf}$$